

# Power Flame Incorporated



## **SUGGESTED SPECIFICATION FOR MODEL JA(R)HTD HIGH TURNDOWN GAS BURNERS**

***THE POWER TO MANAGE ENERGY***

2001 South 21st Street, Parsons, Kansas 67357

Telephone: 620-421-0480, Fax: 620-421-0948

Web Site: [www.powerflame.com](http://www.powerflame.com)

E-Mail: [CSD@powerflame.com](mailto:CSD@powerflame.com)

**Suggested Specifications for Model JA(R)HTD HIGH TURNDOWN  
Gas Burners**

**Table of Contents**

<b><u>Section</u></b>	<b><u>Page(s)</u></b>
General Burner Description .....	1
Burner Control Panel .....	1
Gas Train.....	1
Mode of Operation.....	1
Product Liability Insurance.....	2
Burner Start Up Information and Test Data.....	2-3

**Suggested Specification for Model  
JA(R) HTD HIGH TURNDOWN GAS BURNERS**

**GENERAL BURNER DESCRIPTION**

Furnish and install \_\_\_\_\_ Power Flame Model \_\_\_\_\_ forced draft flame retention natural gas burners. Each burner shall be capable of burning \_\_\_\_\_ CFH of \_\_\_\_\_ BTU/CU.FT. **(natural gas) or (propane gas)**, with a specific gravity of \_\_\_\_\_. Gas pressure supplied to the burner gas train supply connection shall be a minimum of \_\_\_\_\_ **(In. w.c.) (PSIG)** at full high rate and a maximum of \_\_\_\_\_ **(In. w.c.) (PSIG)** at static conditions.

Each burner shall be listed by Underwriters laboratories and shall bear the appropriate UL label. (In addition to the UL requirements, all equipment and installation procedures will meet the requirements of (IRI), (FM), (Other) \_\_\_\_\_ codes). Each burner shall be designed and constructed as an integrated combustion system package - and shall be factory fire tested.

Each burner shall be of welded steel construction and have a baked on powder coat finish. The firing head shall be of the multi port design and incorporate a stainless steel, flame retention diffusor. The burner combustion head will carry full five (5) year replacement warranty.

All air required for combustion shall be supplied by a blower, mounted integral to the burner. The blower wheel shall be of a forward curved "Squirrel Cage" design and shall be directly driven by a \_\_\_\_\_ HP, 3450 RPM \_\_\_\_\_ Volt, 60 Hertz \_\_\_\_\_ phase motor. A dual blade damper assembly shall meter the combustion air flow.

The burner ignition system shall be **(natural gas) or (propane gas)**. The pilot system components shall include spark ignited pilot assembly, 6000 Volt ignition transformer, pilot solenoid valve, pilot pressure regulator and manual gas shutoff cock. The flame proving system shall incorporate an Ultra-Violet detector.

**BURNER CONTROL PANEL**

All control components shall be mounted and wired within an integral burner mounted control panel. The panel shall incorporate an "Easy Access" (lift off) cover and will include Power On and Main Fuel indicating lights and an On/Off control switch.

**GAS TRAIN**

The gas train shall consist of a manual shutoff cock, main gas pressure regulator, main motorized gas valve, auxiliary solenoid gas valve, leak test cock and butterfly type gas flow control valve.

**MODE OF OPERATION**

A modulating motor shall control the positioning of the air inlet dampers and butterfly type gas proportioning valve, to best meet varying system load conditions. The positioning of the modulating motor shall be controlled by **(135 Ohm), 4-20 mA, (0-10 VDC)** modulating type **(temperature), (pressure)** controller. When the operating control is satisfied the burner shall shutoff and return to the low fire start position. The modulating motor shall provide an electrical interlock to insure a guaranteed low fire start position prior to the pilot trial for ignition sequence.

**PRODUCT LIABILITY INSURANCE**

The burner manufacturer will provide an insurance certificate documenting his current coverage of Product Liability Insurance with minimum coverage of \$10,000,000.

**BURNER START UP INFORMATION AND TEST DATA**

On completion of the burner system start up - the installing contractor will complete the attached "Burner Start Up and Test Data" form and deliver to the Specifying Engineer.

# BURNER START UP INFORMATION & TEST DATA

The following information shall be recorded for each burner start up:

Power Flame Model \_\_\_\_\_ Invoice No. \_\_\_\_\_ Serial No. \_\_\_\_\_  
 Installation Name \_\_\_\_\_ Start Up Date \_\_\_\_\_  
 Start Up Contractors Name \_\_\_\_\_ Phone \_\_\_\_\_  
 Name of Technician doing Start Up \_\_\_\_\_  
 Type of Gas:      Nat.  LP  Other       Fuel Oil Grade No. \_\_\_\_\_

## Gas Firing

### Gas Pressure at Train Inlet

Burner in Off Position \_\_\_\_\_

### Gas Pressure at Train Inlet

Low Fire \_\_\_\_\_ " W.C.

High Fire \_\_\_\_\_ " W.C.

### Gas Pressure at Firing Head

Low Fire \_\_\_\_\_ " W.C.

High Fire \_\_\_\_\_ " W.C.

### Gas Pressure at Pilot Test Tee

\_\_\_\_\_ " W.C.

### Power Supply

Volts \_\_\_\_\_ Ph \_\_\_\_\_ Hz \_\_\_\_\_

Control Circuit Volts \_\_\_\_\_

Blower Motor amps at high fire \_\_\_\_\_

### Flame Signal Readings

Pilot \_\_\_\_\_ D.C. Volts

Low Fire \_\_\_\_\_ D.C. Volts

High Fire \_\_\_\_\_ D.C. Volts

### CO<sub>2</sub> or O<sub>2</sub> (Specify)

Low Fire \_\_\_\_\_ %

High Fire \_\_\_\_\_ %

### CO

Low Fire \_\_\_\_\_ %

High Fire \_\_\_\_\_ %

### Input Rate BTU/HR

Low Fire \_\_\_\_\_

High Fire \_\_\_\_\_

### Over Fire Draft

Low Fire \_\_\_\_\_ " W.C.

High Fire \_\_\_\_\_ " W.C.

### Stack Outlet Test Draft

Low Fire \_\_\_\_\_ " W.C.

High Fire \_\_\_\_\_ " W.C.

### Net Stack Temperature

Low Fire \_\_\_\_\_ °F

High Fire \_\_\_\_\_ °F

### Combustion Efficiency

Low Fire \_\_\_\_\_ %

High Fire \_\_\_\_\_ %

### Air Inlet Damper Opening High Fire

Top \_\_\_\_\_ in.

Bottom \_\_\_\_\_ in.

## Control Settings

### General

Operating control cut out setting \_\_\_\_\_

Limit control cut out setting \_\_\_\_\_

Low gas pressure switch \_\_\_\_\_ in.

High gas pressure switch \_\_\_\_\_ in.

Operating control cut in setting \_\_\_\_\_

Limit control cut in setting \_\_\_\_\_

## Operation Checklist

### Checked For Proper Operation Of:

	<u>Yes</u>	<u>No</u>		<u>Yes</u>	<u>No</u>
Low water cut off	_____	_____	Barometric damper	_____	_____
High water cut off	_____	_____	Boiler room combustion air &	_____	_____
Flame safeguard control ignition failure	_____	_____	ventilation provision correct	_____	_____
Flame safeguard control main flame failure	_____	_____	Oil tank vent system correct	_____	_____
Burner air flow switch	_____	_____	All oil lines checked for leaks	_____	_____
Induced draft fan controls	_____	_____	All gas lines checked for leaks	_____	_____
Over fire draft controls	_____	_____	Gas lines & controls properly vented	_____	_____
Fresh air damper end switch	_____	_____	Other system components (specify)	_____	_____

Notified \_\_\_\_\_ of the following system deficiencies: \_\_\_\_\_

---



---